

2025/26 Water Quality Report

FACILITY NAME	SAMPLE TYPE	LOCATION	RESULT (mg/L)	EXCEEDS	REMEDIATION
Arthur Peake Centre	Static	1006 CLASSROOM SINK	0.0064	Yes	2-minute flush
Arthur Peake Centre	With Flush	1006 CLASSROOM SINK 1 MIN	0.0012	No	
Arthur Peake Centre	Static	1019 STAFF SINK KITCHEN	0.0008	No	
Arthur Peake Centre	Static	SHOP CLASSROOM SINK	0.0021	No	
Arthur Peake Centre	Static	1003 CLASSROOM SINK	0.0019	No	
Arthur Peake Centre	Static	1018 BATHROOM SINK	0.0095	Yes	2-minute flush
Arthur Peake Centre	With Flush	1018 BATHROOM SINK 1 MIN	0.00093	No	
Maintenance Facility	Static	1018 KITCHEN SINK	0.0015	No	
Albion Elementary	Static	1840 KITCHEN SINK	0.00076	No	
Albion Elementary	Static	1110 DRINKING FOUNTAIN	0.00074	No	
Albion Elementary	Static	1330 STAFF SINK	0.0019	No	
Albion Elementary	Static	1370 FIRST AID SINK	0.0061	Yes	2-minute flush
Albion Elementary	With Flush	1370 FIRST AID SINK 1 MIN	0.00037	No	
Albion Elementary	Static	1600 DRINKING FOUNTAIN	0.0014	No	
Albion Elementary	Static	1720 CLASS SINK	0.0014	No	
Albion Elementary	Static	1800 CLASS SINK	0.0012	No	
Albion Elementary	Static	1200 BOTTLE FILL	0.0004	No	
Alexander Robinson Elementary	Static	1042 BOTTLE FILL	0.00078	No	
Alexander Robinson Elementary	Static	1043 KITCHEN SINK	0.00037	No	
Alexander Robinson Elementary	Static	2002 STAFF ROOM SINK	0.00039	No	
Alexander Robinson Elementary	Static	1006 NURSE ROOM SINK	0.0013	No	
Blue Mountain Elementary	Static	1037 CLASS SINK	0.00019	No	
Blue Mountain Elementary	Static	1028 DRINK FOUNTAIN	0.00024	No	
Blue Mountain Elementary	Static	1042 CLASS SINK	0.00036	No	
Blue Mountain Elementary	Static	1048 KITCHEN SINK	0.0015	No	
Blue Mountain Elementary	Static	1010 DRINK FOUNTAIN	0.00018	No	
česqenele Elementary (South Albion)	Static	129 STAFF SINK	0.00043	No	
česqenele Elementary (South Albion)	Static	SALMON POD STAFF SINK	0.00043	No	
česqenele Elementary (South Albion)	Static	ORCA POD CLASS SINK	0.00034	No	
česqenele Elementary (South Albion)	Static	107 KITCHEN SINK	0.00035	No	
česqenele Elementary (South Albion)	Static	THUNDER POD CLASS SINK	0.00027	No	
česqenele Elementary (South Albion)	Static	HUMMINGBIRD POD CLASS SINK	0.0004	No	
česqenele Elementary (South Albion)	Static	147 OUTSIDE GYM DW	0.00006	No	
česqenele Elementary (South Albion)	Static	BOBCAT POD CLASS SINK	0.00045	No	
česqenele Elementary (South Albion)	Static	BEAR POD CLASS SINK	0.00031	No	
česqenele Elementary (South Albion)	Static	BEAR POD KITCHEN SINK	0.00022	No	
Garibaldi Secondary	Static	2031 STAFF SINK	0.0015	No	
Garibaldi Secondary	Static	2022A TUBE FEED CUSTODIAL ROOM	0.00013	No	
Garibaldi Secondary	Static	2028C CLASS SINK	0.00021	No	
Garibaldi Secondary	Static	2042 BOTTLE FILL	0.0033	No	
Garibaldi Secondary	Static	2206 STAFF RM SINK	0.0046	No	
Garibaldi Secondary	Static	2227 DRINK FOUNTAIN	0.0019	No	
Garibaldi Secondary	Static	2223 OUTSIDE WASHROOM DRINK FOUNTAIN	0.00034	No	

FACILITY NAME	SAMPLE TYPE	LOCATION	RESULT (mg/L)	EXCEEDS	REMEDIATION
Garibaldi Secondary	Static	2056 FOODS SINK 1	0.00041	No	
Garibaldi Secondary	Static	2056 FOODS SINK 2	0.00045	No	
Garibaldi Secondary	Static	2056 FOODS SINK 3	0.00079	No	
Garibaldi Secondary	Static	2056 FOODS SINK 4	0.0011	No	
Garibaldi Secondary	Static	2056 FOODS SINK 5	0.00035	No	
Garibaldi Secondary	Static	2056 FOODS SINK 6	0.00064	No	
Garibaldi Secondary	Static	2051 CAFÉ KITCH SINK 1	0.00055	No	
Garibaldi Secondary	Static	2051 CAFÉ KITCH SINK 2	0.00054	No	
Garibaldi Secondary	Static	2051 CAFÉ KITCH SINK 3	0.0004	No	
Garibaldi Secondary	Static	2205 FIRST AID SINK	0.0077	Yes	2-minute flush
Garibaldi Secondary	With Flush	2205 FIRST AID SINK 1 MIN	0.00047	No	
Garibaldi Secondary	Static	2210 DRINK FOUNTAIN	0.00068	No	
Kanaka Creek Elementary	Static	1034 MULTIPURPOSE SINK	0.0065	Yes	2-minute flush
Kanaka Creek Elementary	With Flush	1034 MULTIPURPOSE SINK 1 MIN	0.00028	No	
Kanaka Creek Elementary	Static	1031 PAC KITCHEN	0.0065	Yes	2-minute flush
Kanaka Creek Elementary	With Flush	1031 PAC KITCHEN 1 MIN	0.00023	No	
Kanaka Creek Elementary	Static	1021 CLASS SINK	0.00091	No	
Kanaka Creek Elementary	Static	1016 QUIET ROOM SINK KITCHEN	0.0066	Yes	2-minute flush
Kanaka Creek Elementary	With Flush	1016 QUIET ROOM SINK KITCHEN 1 MIN	0.00036	No	
Kanaka Creek Elementary	Static	1008 STAFF SINK KITCHEN	0.0013	No	
Samuel Robertson Technical School	Static	1285 HALL BOTTLE FILL	0.00006	No	
Samuel Robertson Technical School	Static	1285 FOOD SINK 1	0.00057	No	
Samuel Robertson Technical School	Static	1285 FOOD SINK 2	0.00076	No	
Samuel Robertson Technical School	Static	1285 FOOD SINK 3	0.0005	No	
Samuel Robertson Technical School	Static	1285 FOOD SINK 4	0.0004	No	
Samuel Robertson Technical School	Static	1285 FOOD SINK 5	0.00098	No	
Samuel Robertson Technical School	Static	1275 CAFÉ SINK 1	0.0019	No	
Samuel Robertson Technical School	Static	1275 CAFÉ SINK 2	0.0025	No	
Samuel Robertson Technical School	Static	1275 CAFÉ SINK 3	0.00059	No	
Samuel Robertson Technical School	Static	1275 CAFÉ SINK 4	0.0011	No	
Samuel Robertson Technical School	Static	1205 DRINK FOUNTAIN	0.006	Yes	2-minute flush
Samuel Robertson Technical School	With Flush	1205 DRINK FOUNTAIN 1 MIN	0.0017	No	
Samuel Robertson Technical School	Static	1470 LIBRARY SINK	0.0015	No	
Samuel Robertson Technical School	Static	1065 FIRST AID SINK	0.0022	No	
Samuel Robertson Technical School	Static	1080 STAFF SINK	0.00098	No	
Samuel Robertson Technical School	Static	2065 DRINKING FOUNTAIN	0.00005	No	
Websters Corner Elementary	Static	1138 KITCHEN SINK	0.00049	No	
Websters Corner Elementary	Static	1170 CLASS SINK	0.00072	No	
Websters Corner Elementary	Static	1111 STAFF KITCHEN SINK	0.00027	No	
Websters Corner Elementary	Static	1105 CORR DRINK FOUNTAIN	0.00074	No	
Websters Corner Elementary	Static	1115 NURSE SINK	0.0087	Yes	2-minute flush
Websters Corner Elementary	With Flush	1115 NURSE SINK 1 MIN	0.00056	No	